

## Annual CCR Fugitive Dust Control Report

On December 2, 2021, Corporate Environmental met to review the CCR Fugitive Dust Control Plan (Plan) for SGS. This annual evaluation was conducted in accordance with 40 C.F.R. §257.80(c) and Section 3.2 of the Plan.

### **Actions Taken to Control CCR**

The methods used to control CCR fugitive dust at SGS are documented within the Plan. During the annual review, no significant concerns or deficiencies were identified for the methods in the Plan and their effectiveness in controlling CCR fugitive dust at SGS. Any incident involving dusting of CCR was recorded in an incident report as required by the Plan. Upon notification of any dusting of CCR, SGS staff took immediate actions to remove that equipment from service and address any malfunctions.

During the SGS site visit, which occurred on December 2, 2021, all CCR management areas were noted to have no visible dusting. The roads used to transport CCR to the Effluent Processing Facility and the Increment 1 landfill were clean and well maintained. CCR within the landfill was compacted and cover material was properly placed to prevent dusting.

### **Citizen Complaints**

No citizen complaints regarding CCR fugitive dust at SGS were received during the review period.

### **Summary**

After review of the Plan and operations at SGS, SECI Corporate Environmental and SGS Environmental & Process Supports determined that there is not a need for any significant changes to the current Plan.