

Annual CCR Fugitive Dust Control Report

On November 28, 2023, a review of CCR control measures was completed by members of Corporate Environmental and SGS ENV. This annual evaluation was conducted in accordance with 40 C.F.R. §257.80(c) and Section 3.2 of the Plan.

Actions Taken to Control CCR

The methods used to control CCR fugitive dust at SGS are documented within the Plan. During the annual review, no significant concerns or deficiencies were identified for the methods in the Plan and their effectiveness in controlling CCR fugitive dust at SGS. Any incident involving dusting of CCR was recorded in an incident report as required by the Plan. Upon notification of any dusting of CCR, SGS staff took immediate actions to remove that equipment from service and address any malfunctions.

During the SGS site visit, which occurred on November 28, 2023, all CCR management areas were noted to have no visible dusting. The roads used to transport CCR to the Effluent Processing Facility and the Increment 1 landfill were clean and well maintained. CCR within the landfill was compacted and cover material was properly placed to prevent dusting.

Citizen Complaints

No citizen complaints regarding CCR fugitive dust at SGS were received during the review period.

Summary

After review of the Plan and operations at SGS it was determined that no changes to the current plan were necessary.